

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Optional modules for building-in (DIN RAIL)

Name and address of the applicant

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the manufacturer

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the factory

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

See page 3

Trademark / Brand (if any)

TRACO POWER

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 61010-1:2010 + A1:2019 and EN IEC 61010-2-201:2018; National Differences specified in the CB Test Reports.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016
IEC 61010-2-201: 2017

As shown in the Test Report Ref. No. which forms part of this Certificate

T223-0832/20, T223-0833/20 (2020-12-15)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2020-12-15

Signature: Bojan Pečavar



Model / Type Ref.:

TRACO POWER Model reference	Manufacturer Drawing reference
TSP-BCM12	240BCM122
TSP-BCM24	240BCM144
TSP-BCM48	240BCM155
TSP-BCM24A	480BCM144
TSP-BCM48A	480BCM155
TSP-BFM24	480BUF144
TSP-REM360	240REM144
TSP-REM600	480REM144
TSPC-DCM600	480ISO144
TSP-BCMU360	360PSN149USV

Models can be additional marked with xxaaaaa, where 'x' or 'a' can be any alphanumeric, blank or dash, no impact on safety.

Additional information (if necessary)

Date: 2020-12-15

Signature: Bojan Pečavar



Ratings and principal characteristics:

Model	Input		Output	
	Voltage [V d.c.]	Current [A]	Voltage [V d.c.]	Current [A]
TSP-BCM12	DC-IN: 12 BATT-IN: 12	12,0	12	12,0
TSP-BCM24	DC-IN: 24 BATT-IN: 24	15,0	24	15,0
TSP-BCM48	DC-IN: 48 BATT-IN: 48	6,4	48	6,4
TSP-BCM24A	DC-IN: 24 BATT-IN: 24	25,0	24	25,0
TSP-BCM48A	DC-IN: 48 BATT-IN: 48	11,0	48	11,0
TSP-BFM24	24-28	Max. 25,0	24-28	Max. 25,0
TSP-REM360	Input1: 24 Input2: 24	15,0	24	15,0
TSP-REM600	Input1: 24 Input2: 24	25,0	24	25,0
TSPC-DCM600	Input1: 24 Input2: 24	25,0	24	25,0
TSP-BCMU360	Input1: 24/48 Input2: 24/48 BATT-IN: 13,8	15,0/7,5 15,0/7,5 30,0	24/48 24/48 22,4/44,9	15,0/7,5 15,0/7,5 10,0/5,0

Additional information (if necessary)

Date: 2020-12-15

Signature: Bojan Pečavar

